

Our Ref: HL/M90327

26th October 2009

Arkema,
Usine de Serquigny,
Route du Rilsan,
27470 Serquigny,
France

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

COATINGS, PAINTS & LININGS - FACTORY APPLIED PIPE & FITTINGS COATINGS 5030

Rilsan polyamide powder coatings to be used in conjunction with Primgreen LAT 12035 epoxy resin primer. The following grades are for use with hot and cold water up to 60°C:

T Black 7450 AC, T Blue 7443 MAC, T Green 7529 MAC, T Grey 5161 MAC and T White 1488 AC.

Test Report: MA3938/F

0910504

ARKEMA

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Material" or "WRAS - Approved Material". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in October 2014.

Yours faithfully



Hannah Lewis
WRAS Approvals Administrator
Water Regulations Advisory Scheme